

## Data Sheet

### Water installations

#### 1. Contact person

Leipziger Messe GmbH  
Technical Event Management Department (TI-VT)

Messe Allee 1  
04356 Leipzig

Tel.: 0341 / 678 - 9906  
E-Mail: [veranstaltungstechnik@leipziger-messe.de](mailto:veranstaltungstechnik@leipziger-messe.de)

This department coordinates all required boundary conditions with the company's project manager.

#### 2. Application area and principles

This data sheet applies solely to the premises of Leipziger Messe GmbH in connection with an order for water installations.

#### 3. Requirements and information

By placing an order for a drinking water connection, the client commits to comply with the German Drinking Water Regulation (TrinkwV) during the use of the connection. This means that the installation and operation of a connection excludes any negative impacts on drinking water quality. Leipziger Messe GmbH will provide a drinking water connection up to the client's withdrawal point:

Please note:

- During the installation:
  - Adherence to generally recognised rules of technology
  - Work on water installations at the stand may only be performed by an authorised plumber
  - Exclusive use of suitable materials, i.e. pipe sections and building components that are specially approved for drinking water, are clean and pressure-resistant and undamaged, see also sec. 17 TrinkwV
  - Use of shortest possible connections with small cross-sections between the transfer and withdrawal point
  - Prior to initial and renewed start-up, thorough cleaning and rinsing of entire system, disinfection pursuant to the DVGW Work Sheet W 291, followed by full rinse of disinfectant residue
- During operation:
  - Protect connections and system against dirt, damages and destruction
  - Prevent backflow into the distribution system pursuant to generally recognised rules of technology
  - System is only used for drinking water purposes
  - Daily inspection of water supply system for soundness
- A fixed drinking water connection is required if the drinking water is used for the preparation of meals and beverages. Water from containers may not be used for this purpose.
- Special requirements apply to trade fairs involving the presence of animals. In addition to adequate cleaning procedures, you must ensure that faecal matter or other materials (e.g. cleaning agents) do not come into contact with the supply facilities. Floors must be covered to ensure that contamination does not reach the installation channels.

- Due to the potential transfer of pathogens (e.g. Legionella) through aerosol-forming facilities (e.g. whirlpools), these systems can only be used in the trade fair halls with cold water.

#### 4. Implementation

Use may only be commenced once all boundary conditions and requirements have been met.